



City of El Cajon
Building and Fire Safety Division
200 E. Main St.
El Cajon, CA 92020
Phone: (619) 441-1726, 1727
Inspection Request Line (619) 440-0481

Vehicle(s) Indoor

Please read and be aware of the following information!

In order to permit a vehicle(s) indoor, two copies of a site plan showing the location of the vehicle(s) must be submitted along with a permit application.

Note - Call for an inspection a minimum of one working day before the requested date of inspection (**Inspection request line – (619) 441-6210**).

The following are requirements for vehicle(s) indoor within the City of El Cajon.

- Display of liquid and gas-fueled vehicles and equipment inside an assembly occupancy shall be in accordance with article 2505 of the California Fire Code.
- Batteries shall be disconnected in an approved manner (CFC 314.1 #1).
- Vehicles shall not be fueled or defueled within the building (CFC 314.4 #4).
- Fuel in the tank shall not exceed one quarter of the tank capacity or 5 gallons whichever is less (CFC 314.4 #2)
- Fuel systems shall be inspected for leaks
- Fuel tank openings shall be locked and sealed to prevent the escape of vapors (CFC 314.4 #3).
- The location of vehicles or equipment shall not obstruct or block means of egress (CFC 1003.3.4).

If you have any questions concerning the display of vehicles inside of a building please call the Building and Fire Safety Division prior to the date of vehicle placement .